

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/01/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155487		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/25/2013	
NAME OF PROVIDER OR SUPPLIER BROWN COUNTY HEALTH AND LIVING COMMUNITY				STREET ADDRESS, CITY, STATE, ZIP CODE 55 E WILLOW ST NASHVILLE, IN 47448			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 12/05/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 01/25/13</p> <p>Facility Number: 000479 Provider Number: 155487 Aim Number: 100290880</p> <p>Surveyor: Phillip Komsiski, Life Safety Code Specialist</p> <p>At this PSR survey, Brown County Health and Living Community was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The original building was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors, with battery operated smoke detectors in all resident rooms except on E-hall rooms E 7 through E 14 where the smoke detectors were hard wired. The facility has a capacity of 116 and had a census of 111 at the time of this survey.</p> <p>All areas where the residents have customary</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/01/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155487		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/25/2013	
NAME OF PROVIDER OR SUPPLIER BROWN COUNTY HEALTH AND LIVING COMMUNITY				STREET ADDRESS, CITY, STATE, ZIP CODE 55 E WILLOW ST NASHVILLE, IN 47448			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE			
{K 000}	Continued From page 1 access were sprinklered. All areas providing facility services were sprinklered, except for an outside shed used for maintenance equipment and holiday decorations which is not sprinklered.	{K 000}					
{K 000}	Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 01/31/13. INITIAL COMMENTS A Post Survey Revisit (PSR) to the Life Safety Code Recertification and State Licensure Survey conducted on 12/05/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a). Survey Date: 01/25/13 Facility Number: 000479 Provider Number: 155487 Aim Number: 100290880 Surveyor: Phillip Komsiski, Life Safety Code Specialist At this PSR survey, Brown County Health and Living Community was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The 2008 addition consisting of the Therapy room and lobby was surveyed with Chapter 18, New Health Care Occupancies. This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system	{K 000}					

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/01/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155487		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 03 B. WING _____		(X3) DATE SURVEY COMPLETED R 01/25/2013	
NAME OF PROVIDER OR SUPPLIER BROWN COUNTY HEALTH AND LIVING COMMUNITY				STREET ADDRESS, CITY, STATE, ZIP CODE 55 E WILLOW ST NASHVILLE, IN 47448			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>Continued From page 2</p> <p>with smoke detection in the corridors, spaces open to the corridors, with battery operated smoke detectors in all resident rooms except on E-hall rooms E 7 through E 14 where the smoke detectors were hard wired. The facility has a capacity of 116 and had a census of 111 at the time of this survey.</p> <p>All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered, except an outside shed used for maintenance equipment and holiday decorations which is not sprinklered.</p>			{K 000}			